

**Indiana Department of Environmental Management
OWM - Drinking Water Branch
Synthetic Organic Compounds in Drinking Water**

Return Completed Form to: Indiana Department of Environmental Management P.O. Box 7148 Indianapolis, IN 46207-7148	Sample Receipt Date: 03/29/00 QA Review Date: 04/24/00 Report Date: 04/24/00 PWSID #: 5222220	Laboratory Name: Brookside Labs Inc Laboratory Certification: C-OH 05 Laboratory Report #: DI0329051 Contact Person: Steven D. Weil Phone Number: 419 753 2448
Date Sample: 03/28/00 Sample ID: DI0329051 Sample Type: <input type="checkbox"/> Routine - Annual <input type="checkbox"/> Routine - Quarterly <input type="checkbox"/> Detection Monitoring <input type="checkbox"/> Confirmation Sample <input type="checkbox"/> Special Purpose	PWS Facility Name: Joe Smith PWS Address: 1210 NW 250 E Somewhere, IN 47474 Sampling Site: 1 Comments:	
Location Code:		

Does the system chlorinate their water?	<input type="checkbox"/> Yes	<input type="checkbox"/> No	Was the sample dechlorinated at the laboratory?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
---	------------------------------	-----------------------------	---	------------------------------	-----------------------------

Has this information been sent to IDEM by the laboratory?	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No
---	------------------------------	--

Field Treatment:	<input type="checkbox"/> Iced	<input checked="" type="checkbox"/> Na2S2O3	<input checked="" type="checkbox"/> HCl	<input type="checkbox"/> H2SO4	<input type="checkbox"/> CH2ClCOOH	<input type="checkbox"/> Other (explain)
------------------	-------------------------------	---	---	--------------------------------	------------------------------------	--

Com-pound ID #	Parameter	Method #	Analysis Date	D.L. ug/L	Result ug/L	MCL ug/L	Com-pound ID #	Parameter	Method #	Analysis Date	D.L. ug/L	Result ug/L
Regulated Contaminants							Unregulated Contaminants					
2051	Alachlor (Lasso)	525.2	04/06	0.2	<0.2	2	2047	Aldicarb	531.1			0.7
2050	Atrazine	525.2	04/06	0.3	<0.3	3	2044	Aldicarb Sulfone	531.1			0.7
2306	Benzo(a)pyrene	525.2		0.02		0.2	2043	Aldicarb Sulfoxide	531.1			0.7
2046	Carbofuran	531.1		0.5		40	2356	Aldrin	508			30
2959	Chlordane (alpha & gamma)	508	04/05	0.2	<0.2	2	2076	Butachlor	525.2			10
2105	2,4-D	515.1	04/07	7	<7	70	2021	Carbaryl	531.1			10
2031	Dalapon	515.1	04/07	20	<20	200	2440	Dicamba	515.1			10
2931	DBCP	504.1	04/04	0.02	<0.02	0.2	2070	Dieldrin	508			20
2041	Dinoseb	515.1	04/07	0.7	<0.7	7	2066	3-Hydroxycarbofuran	531.1			10
2063	2,3,7,8-TCDD (Dioxin)					3X10-5	2022	Methomyl	531.1			50
2032	Diquat	549.1		2		20	2045	Metolachlor	525.2			5
2035	Di(2-ethylhexyl)adipate	525.2	04/06	40	<40	400	2595	Metribuzin	525.2			1
2039	Di(2-ethylhexyl)phthalate	525.2	04/06	0.6	<0.6	0.69	2077	Propachlor	525.2			10
2033	Endothall	548.1	04/05	10	<10	100						
2005	Endrin	508	04/05	0.2	<0.2	0.2						
2946	Ethylene Dibromide (EDB)	504.1	04/04	0.02	<0.02	0.05						
2034	Glyphosate (Round-up)	547		70		700						
2065	Heptachlor	508	04/05	0.04	<0.04	0.4						
2067	Heptachlor Epoxide	508	04/05	0.02	<0.02	0.2						
2274	Hexachlorobenzene	508	04/05	0.1	<0.1	1						
2042	Hexachlorocyclopentadiene	508	04/05	5	<5	50						
2010	Lindane	508	04/05	0.02	<0.02	0.2						
2015	Methoxychlor	508	04/05	4	<4	40						
2036	Oxamyl (Vydate)	531.1		20		200						
2326	Pentachlorophenol	515.1	04/07	0.1	<0.1	1						
2040	Picloram (Tordon)	515.1	04/07	50	<50	500						
2383	PCBs	508		0.1		0.5						
2037	Simazine	525.2	04/06	0.4	<0.4	4						
2110	2,4,5-TP (Silvex)	515.1	04/07	5	<5	50						
2020	Toxaphene	508	04/05	1	<1	3						

Reviewed by: by:	Date:	Finalized by: <i>Steve D. Weil</i>	Date: 4/24/00
------------------	-------	------------------------------------	---------------