

**Indiana Department of Environmental Management
 OWM - Drinking Water Branch
 Inorganic Chemicals in Drinking Water**

Return Completed Form to: Indiana Department of Environmental Management P.O. Box 7148 Indianapolis, IN 46207-7148	Sample Receipt Date: 03/28/00 QA Review Date: 04/24/00 Report Date: 04/24/00 PWSID #: 5222220	Laboratory Name: Brookside Labs Inc. Laboratory Certificat C-OH-05 Laboratory Report #: DI0328009 Contact Person: Steven D. Weil Phone Number: 419 753 2448
Date Sampl 03/27/00 Sample ID# DI0328009 Sample Typ Water	PWS Facility Name: Joe Smith PWS Address: 1210 NW 250 E Somewhere, IN 47474 Sampling Site: 1	
<input type="checkbox"/> Routine - Annual <input type="checkbox"/> Routine - Quarterly <input type="checkbox"/> Detection Monitoring <input type="checkbox"/> Confirmation Sample <input type="checkbox"/> Special Purpose	Comments:	

Location Code:

Does the system chlorinate their water? Yes No Was the sample dechlorinated at the laboratory? Yes No

Has this information been sent to IDEM by the laboratory? Yes No

Field Treatment: Iced HNO3 NaOH Other (explain) H2SO4

Com- pound ID #	Parameter	Method #	Analysis Date	D.L. mg/L	Result mg/L	MCL mg/L	Com- pound ID #	Parameter	Method #	Analysis Date	D.L. mg L	Result mg L
Regulated Contaminants							Unregulated Contaminants					
1074	Antimony	EPA200.9	04/06	0.003	<0.003	0.006	1055	Sulfate				
1005	Arsenic	EPA200.9	04/06	0.002	<0.0025	0.05						
1010	Barium	EPA200.7	03/30	0.02	0.05	2						
1075	Beryllium	EPA200.9	04/06	0.00025	<0.00025	0.004						
1015	Cadmium	EPA200.9	04/06	0.0001	0.0008	0.005						
1020	Chromium	EPA200.9	04/06	0.0015	<0.0015	0.1						
1024	Cyanide (free)	E4500CN	03/30	0.02	<0.02	0.2						
1025	Fluoride (Adjusted)	EPA340.2	04/06	0.2	<0.2	2						
1025	Fluoride (Natural)					4						
1035	Mercury	EPA245.1	03/30	0.0002	<0.0002	0.002						
1036	Nickel	EPA200.9	04/06	0.004	<0.004	0.1						
1045	Selenium	EPA200.9	04/06	0.0025	<0.0025	0.05						
1085	Thallium	EPA200.9	04/06	0.0012	<0.0012	0.002						
		Method #	Analysis Date	D.L. mg/L	Result mg/L	MCL mg/L						
1040	Nitrate	SM4500E	04/05	0.01	<0.01	10						
1041	Nitrite	SM4500N		0.005		1						
	Nitrate + Nitrite					10						
		Method #	Analysis Date	D.L. MFL	Result MFL	MCL MFL						
1094	Asbestos					7						

Reviewed by: _____ Date: _____ Finalized by: *Steven D. Weil* Date: *4/24/00*