

**Indiana Department of Environmental Management  
 OWM - Drinking Water Branch  
 Volatile Organic Compounds in Drinking Water**

Return Completed Form to: Indiana Department of Environmental Management P.O. Box 7148 Indianapolis, IN 46207-7148	Sample Receipt Date: 03/15/00 QA Review Date: 04/14/00 Report Date: 04/14/00 PWSID #: 5222220	Laboratory Name: Brookside Labs Inc Laboratory Certification # C-OH-05 Laboratory Report #: DI0315015 Contact Person: Steven D. Weil Phone Number: 419 755 2445
Date Sample: 03/13/00 Sample ID#: DI0315015 Sample Type: Water <input type="checkbox"/> Routine - Annual <input type="checkbox"/> Routine - Quarterly <input type="checkbox"/> Detection Monitoring <input type="checkbox"/> Confirmation Sample <input type="checkbox"/> Special Purpose	PWS Facility Name: Joe Smith PWS Address: 1210 NW 250 E Somewhere, IN 47474 Sampling Site: 1 Comments:	

Location Code: \_\_\_\_\_

Does the system chlorinate their water?  Yes  No      Was the sample dechlorinated at the laboratory?  Yes  No

Has this information been sent to IDEM by the laboratory?  Yes  No

Field Treatment:  Iced  Na2S2O3  HCl  Ascorbic Acid  Other (explain)

Compound ID #	Parameter	Method #	Analysis Date	D.L. mg/L	Result mg/L	MCL mg/L	Compound ID #	Parameter	Method #	Analysis Date	D.L. mg/L	Result mg/L
<b>Regulated Contaminants</b>							<b>Unregulated Contaminants</b>					
2990	Benzene	524.2	03/22	0.0005	<0.0005	0.005	2993	Bromobenzene	524.2	03/22	0.0005	<0.0005
2982	Carbon Tetrachloride	524.2	03/22	0.0005	<0.0005	0.005	2214	Bromomethane	524.2	03/22	0.0005	<0.0005
2989	Chlorobenzene	524.2	03/22	0.0005	<0.0005	0.1	2216	Chloroethane	524.2	03/22	0.0005	<0.0005
2968	1,2-Dichlorobenzene	524.2	03/22	0.0005	<0.0005	0.6	2210	Chloromethane	524.2	03/22	0.0005	<0.0005
2969	1,4-Dichlorobenzene	524.2	03/22	0.0005	<0.0005	0.075	2965	1,2-Chlorotoluene	524.2	03/22	0.0005	<0.0005
2980	1,2-Dichloroethane	524.2	03/22	0.0005	<0.0005	0.005	2956	1,4-Chlorotoluene	524.2	03/22	0.0005	<0.0005
2977	1,1-Dichloroethylene	524.2	03/22	0.0005	<0.0005	0.007	2967	1,3-Dichlorobenzene	524.2	03/22	0.0005	<0.0005
2972	1,2-Dichloroethylene, cis	524.2	03/22	0.0005	<0.0005	0.07	2978	1,1-Dichloroethane	524.2	03/22	0.0005	<0.0005
2979	1,2-Dichloroethylene, tra	524.2	03/22	0.0005	<0.0005	0.1	2412	1,3-Dichloropropane	524.2	03/22	0.0005	<0.0005
2964	Dichloromethane	524.2	03/22	0.0005	<0.0005	0.005	2416	2,2-Dichloropropane	524.2	03/22	0.0005	<0.0005
2983	1,2-Dichloropropane	524.2	03/22	0.0005	<0.0005	0.005	2410	1,1-Dichloropropene	524.2	03/22	0.0005	<0.0005
2992	Ethylbenzene	524.2	03/22	0.0005	<0.0005	0.7	2413	1,3-Dichloropropene (cis &	524.2	03/22	0.0005	<0.0005
2996	Styrene	524.2	03/22	0.0005	<0.0005	0.1	2986	1,1,1,2-Tetrachloroethane	524.2	03/22	0.0005	<0.0005
2987	Tetrachloroethylene	524.2	03/22	0.0005	<0.0005	0.005	2988	1,1,2,2-Tetrachloroethane	524.2	03/22	0.0005	<0.0005
2991	Toluene	524.2	03/22	0.0005	<0.0005	1	2414	1,2,3-Trichloropropane	524.2	03/22	0.0005	<0.0005
2378	1,2,4-Trichlorobenzene	524.2	03/22	0.0005	<0.0005	0.07	2408	Dibromomethane	524.2	03/22	0.0005	<0.0005
2981	1,1,1-Trichloroethane	524.2	03/22	0.0005	<0.0005	0.2	2943	Bromodichloromethane	524.2	03/22	0.0005	<0.0005
2985	1,1,2-Trichloroethane	524.2	03/22	0.0005	<0.0005	0.005	2942	Bromoform	524.2	03/22	0.0005	<0.0005
2984	Trichloroethylene	524.2	03/22	0.0005	<0.0005	0.005	2944	Chlorodibromomethane	524.2	03/22	0.0005	<0.0005
2976	Vinyl Chloride	524.2	03/22	0.0005	<0.0005	0.002	2941	Chloroform	524.2	03/22	0.0005	<0.0005
2955	Total Xylenes	524.2	03/22	0.0005	<0.0005	10						
2995	1,3-Xylenes	524.2	03/22	0.0005	<0.0005							
2997	1,2-Xylenes	524.2	03/22	0.0005	<0.0005							
2962	1,4-Xylenes	524.2	03/22	0.0005	<0.0005							

Reviewed by: \_\_\_\_\_ Date: \_\_\_\_\_ Finalized by: *Steve H. Whit* Date: *4/24/00*